



ANNEX D1

CALIBRATION CERTIFICATES (ONSITE
SENSORS)

ONSITE EQUIPMENT VALIDATION RECORD

Product Information:

Report No.:	ZR/T CS.004-2025-10-Z16		
Product Model:	MAS Dust	Serial No.:	dev9204Z250800016
Issue Date:	2025-11-12		
Version	V3.0_20251112		

Traceability of Calibration Instrument:

Test Item	Calibration Instrument
PM _{2.5} (FSP)	Transfer Standard: dev9204Z250800011
PM ₁₀ (RSP)	Location: M13 Rolling Hill – Rooftop Area
	Collocation Data Period: 2025-10-24 06:40 to 2025-10-24 09:50

Calibration Result:

RSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	0.70	<input checked="" type="checkbox"/> FAIL
<i>Linearity (R²)</i>	> 0.70	0.93	<input checked="" type="checkbox"/> PASS
<i>If Tier 1 fails, Conc. Range will be checked</i>	$RSP \leq 30 \mu\text{g}/\text{m}^3$ is low conc. range	9.7 $\mu\text{g}/\text{m}^3$	Not applicable.
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 8 \mu\text{g}/\text{m}^3$ for RSP	1.2 $\mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS


Remark: Follow QAQC Protocol Path 2 which is Criteria Tier 1 failed while Tier 2 passed.

FSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	0.52	<input checked="" type="checkbox"/> FAIL
<i>Linearity (R²)</i>	> 0.70	0.75	<input checked="" type="checkbox"/> PASS
<i>If Tier 1 fails, Conc. Range will be checked</i>	$FSP \leq 25 \mu\text{g}/\text{m}^3$ is low conc. range	2.5 $\mu\text{g}/\text{m}^3$	If Tier 1 criteria are not met due to narrow range of PM concentration, during the collocation period, Tier 2 will apply.
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 5 \mu\text{g}/\text{m}^3$ for FSP	0.4 $\mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS

Remark: Follow QAQC Protocol Path 2 which is Criteria Tier 1 failed while Tier 2 passed.





QAQC Protocol chart flow



Conclusion:

The report approves that each calibrated item of the product meets its technical specifications.
No calibration action is needed during this time.

Prepared by:	Yannis Qiu	Reviewed by:	George Zhang
--------------	------------	--------------	--------------

ONSITE EQUIPMENT VALIDATION RECORD

Product Information:

Report No.:	ZR/T CS.004-2025-10-Z15		
Product Model:	MAS Dust	Serial No.:	dev9204Z250800015
Issue Date:	2025-11-12		
Version	V3.0_20251112		

Traceability of Calibration Instrument:

Test Item	Calibration Instrument
PM _{2.5} (FSP)	Transfer Standard: dev9204Z250800012
PM ₁₀ (RSP)	Location: M14 Rolling Hill – Outside of Rolling Hill
	Collocation Data Period: 2025-10-24 06:40 to 2025-10-24 09:50

Calibration Result:

RSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	1.09	<input checked="" type="checkbox"/> PASS
<i>Linearity (R²)</i>	> 0.70	0.93	<input checked="" type="checkbox"/> PASS
<i>If Tier 1 fails, Conc. Range will be checked</i>	$RSP \leq 30 \mu\text{g}/\text{m}^3$ is low conc. range	$4.0 \mu\text{g}/\text{m}^3$	Not applicable
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 8 \mu\text{g}/\text{m}^3$ for RSP	$2.5 \mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS


Remark: Follow QAQC Protocol Path 1 which is Criteria Tier 1 and Tier 2 passed.

FSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	1.19	<input checked="" type="checkbox"/> PASS
<i>Linearity (R²)</i>	> 0.70	0.73	<input checked="" type="checkbox"/> PASS
<i>If Tier 1 fails, Conc. Range will be checked</i>	$FSP \leq 25 \mu\text{g}/\text{m}^3$ is low conc. range	$0.6 \mu\text{g}/\text{m}^3$	Not applicable
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 5 \mu\text{g}/\text{m}^3$ for FSP	$1.2 \mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS

Remark: Follow QAQC Protocol Path 1 which is Criteria Tier 1 and Tier 2 passed.





QAQC Protocol chart flow



Conclusion:

The report approves that each calibrated item of the product meets its technical specifications.
No calibration action is needed during this time.

Prepared by:	Yannis Qiu	Reviewed by:	George Zhang
--------------	------------	--------------	--------------

ONSITE EQUIPMENT VALIDATION RECORD

Product Information:

Report No.:	ZR/T CS.004-2025-10-Z13		
Product Model:	MAS Dust	Serial No.:	dev9204Z250800013
Issue Date:	2025-11-12		
Version	V3.0_20251112		

Traceability of Calibration Instrument:

Test Item	Calibration Instrument
PM _{2.5} (FSP)	Transfer Standard: dev9204Z250800012
PM ₁₀ (RSP)	Location: M11 Shek Wu Wai
	Collocation Data Period: 2025-10-24 12:10 to 2025-10-24 15:20

Calibration Result:

RSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	0.82	<input checked="" type="checkbox"/> PASS
<i>Linearity (R²)</i>	> 0.70	0.94	<input checked="" type="checkbox"/> PASS
<i>If Tier 1 fails, Conc. Range will be checked</i>	$RSP \leq 30 \mu\text{g}/\text{m}^3$ is low conc. range	$15.0 \mu\text{g}/\text{m}^3$	Not applicable.
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 8 \mu\text{g}/\text{m}^3$ for RSP	$1.0 \mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS


Remark: Follow QAQC Protocol Path 1 which is Criteria Tier 1 and Tier 2 passed.

FSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	0.79	<input checked="" type="checkbox"/> PASS
<i>Linearity (R²)</i>	> 0.70	0.42	<input type="checkbox"/> FAIL
<i>If Tier 1 fails, Conc. Range will be checked</i>	$FSP \leq 25 \mu\text{g}/\text{m}^3$ is low conc. range	$0.7 \mu\text{g}/\text{m}^3$	If Tier 1 criteria are not met due to narrow range of PM concentration, during the collocation period, Tier 2 will apply.
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 5 \mu\text{g}/\text{m}^3$ for FSP	$3.7 \mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS

Remark: Follow QAQC Protocol Path 2 which is Criteria Tier 1 failed while Tier 2 passed.





QAQC Protocol chart flow



Conclusion:

The report approves that each calibrated item of the product meets its technical specifications.
No calibration action is needed during this time.

Prepared by:	Yannis Qiu	Reviewed by:	George Zhang
--------------	------------	--------------	--------------



ONSITE EQUIPMENT VALIDATION RECORD

Product Information:

Report No.:	ZR/T CS.004-2025-10-Z14		
Product Model:	MAS Dust	Serial No.:	dev9204Z250800014
Issue Date:	2025-11-12		
Version	V2.0_20251112		

Traceability of Calibration Instrument:

Test Item	Calibration Instrument
PM _{2.5} (FSP)	Transfer Standard: dev9204Z250800011
PM ₁₀ (RSP)	Location: M06 Mai Po San Tsuen
	Collocation Data Period: 2025-10-24 12:10 to 2025-10-24 15:20

Calibration Result:

RSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	1.34	<input checked="" type="checkbox"/> FAIL
<i>Linearity (R²)</i>	> 0.70	0.93	<input checked="" type="checkbox"/> PASS
<i>If Tier 1 fails, Conc. Range will be checked</i>	$RSP \leq 30 \mu\text{g}/\text{m}^3$ is low conc. range	11.8 $\mu\text{g}/\text{m}^3$	If Tier 1 criteria are not met due to narrow range of PM concentration, during the collocation period, Tier 2 will apply.
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 8 \mu\text{g}/\text{m}^3$ for RSP	1.9 $\mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS


Remark: Follow QAQC Protocol Path 2 which is Criteria Tier 1 failed while Tier 2 passed.

FSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	0.81	<input checked="" type="checkbox"/> PASS
<i>Linearity (R²)</i>	> 0.70	0.51	<input checked="" type="checkbox"/> FAIL
<i>If Tier 1 fails, Conc. Range will be checked</i>	$FSP \leq 25 \mu\text{g}/\text{m}^3$ is low conc. range	1.1 $\mu\text{g}/\text{m}^3$	If Tier 1 criteria are not met due to narrow range of PM concentration, during the collocation period, Tier 2 will apply.
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 5 \mu\text{g}/\text{m}^3$ for FSP	1.6 $\mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS

Remark: Follow QAQC Protocol Path 2 which is Criteria Tier 1 failed while Tier 2 passed.





QAQC Protocol chart flow



Conclusion:

The report approves that each calibrated item of the product meets its technical specifications.
No calibration action is needed during this time.

Prepared by:	Yannis Qiu	Reviewed by:	George Zhang
--------------	------------	--------------	--------------

ONSITE EQUIPMENT VALIDATION RECORD

Product Information:

Report No.:	ZR/T CS.004-2025-10-Z19		
Product Model:	MAS Dust	Serial No.:	dev9204Z250900019
Issue Date:	2025-11-12		
Version	V2.0_20251112		

Traceability of Calibration Instrument:

Test Item	Calibration Instrument
PM _{2.5} (FSP)	Transfer Standard: dev9204Z250800011
PM ₁₀ (RSP)	Location: M15a The STEP
	Collocation Data Period: 2025-10-17 12:40 to 2025-10-17 15:50

Calibration Result:

RSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	0.30	<input checked="" type="checkbox"/> FAIL
<i>Linearity (R²)</i>	> 0.70	0.28	<input checked="" type="checkbox"/> FAIL
<i>If Tier 1 fails, Conc. Range will be checked</i>	$RSP \leq 30 \mu\text{g}/\text{m}^3$ is low conc. range	$10.3 \mu\text{g}/\text{m}^3$	If Tier 1 criteria are not met due to narrow range of PM concentration, during the collocation period, Tier 2 will apply.
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 8 \mu\text{g}/\text{m}^3$ for RSP	$2.3 \mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS


Remark: Follow QAQC Protocol Path 2 which is Criteria Tier 1 failed while Tier 2 passed.

FSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	0.78	<input checked="" type="checkbox"/> PASS
<i>Linearity (R²)</i>	> 0.70	0.59	<input checked="" type="checkbox"/> FAIL
<i>If Tier 1 fails, Conc. Range will be checked</i>	$FSP \leq 25 \mu\text{g}/\text{m}^3$ is low conc. range	$1.9 \mu\text{g}/\text{m}^3$	If Tier 1 criteria are not met due to narrow range of PM concentration, during the collocation period, Tier 2 will apply.
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 5 \mu\text{g}/\text{m}^3$ for FSP	$0.4 \mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS

Remark: Follow QAQC Protocol Path 2 which is Criteria Tier 1 failed while Tier 2 passed.





QAQC Protocol chart flow



Conclusion:

The report approves that each calibrated item of the product meets its technical specifications.
No calibration action is needed during this time.

Prepared by:	Yannis Qiu	Reviewed by:	George Zhang
--------------	------------	--------------	--------------

ONSITE EQUIPMENT VALIDATION RECORD

Product Information:

Report No.:	ZR/T CS.004-2025-10-Z05		
Product Model:	MAS Dust	Serial No.:	dev9204Z250700005
Issue Date:	2025-11-12		
Version	V3.0_20251112		

Traceability of Calibration Instrument:

Test Item	Calibration Instrument
PM _{2.5} (FSP)	Transfer Standard: dev9204Z250800011
PM ₁₀ (RSP)	Location: M09 Wing Ping Tsuen
	Collocation Data Period: 2025-10-17 06:40 to 2025-10-17 09:50

Calibration Result:

RSP:



Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	0.88	<input checked="" type="checkbox"/> PASS
<i>Linearity (R²)</i>	> 0.70	0.94	<input checked="" type="checkbox"/> PASS
<i>If Tier 1 fails, Conc. Range will be checked</i>	$RSP \leq 30 \mu\text{g}/\text{m}^3$ is low conc. range	$15.8 \mu\text{g}/\text{m}^3$	Not applicable
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 8 \mu\text{g}/\text{m}^3$ for RSP	$2.6 \mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS


Remark: Follow QAQC Protocol Path 1 which both Criteria Tier 1 and Tier 2 passed.

FSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	0.96	<input checked="" type="checkbox"/> PASS
<i>Linearity (R²)</i>	> 0.70	0.96	<input checked="" type="checkbox"/> PASS
<i>If Tier 1 fails, Conc. Range will be checked</i>	$FSP \leq 25 \mu\text{g}/\text{m}^3$ is low conc. range	$4.8 \mu\text{g}/\text{m}^3$	Not applicable
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 5 \mu\text{g}/\text{m}^3$ for FSP	$0.9 \mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS

Remark: Follow QAQC Protocol Path 1 which both Criteria Tier 1 and Tier 2 passed.





QAQC Protocol chart flow



Conclusion:

The report approves that each calibrated item of the product meets its technical specifications.
No calibration action is needed during this time.

Prepared by:	Yannis Qiu	Reviewed by:	George Zhang
--------------	------------	--------------	--------------

ONSITE EQUIPMENT VALIDATION RECORD

Product Information:

Report No.:	ZR/T CS.004-2025-10-Z06		
Product Model:	MAS Dust	Serial No.:	dev9204Z250700006
Issue Date:	2025-11-12		
Version	V2.0_20251112		

Traceability of Calibration Instrument:

Test Item	Calibration Instrument
PM _{2.5} (FSP)	Transfer Standard: dev9204Z250800012
PM ₁₀ (RSP)	Location: M04 Chau Tau Tsuen
	Collocation Data Period: 2025-10-17 06:40 to 2025-10-17 09:50

Calibration Result:

RSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	0.72	<input checked="" type="checkbox"/> FAIL
<i>Linearity (R²)</i>	> 0.70	0.91	<input checked="" type="checkbox"/> PASS
<i>If Tier 1 fails, Conc. Range will be checked</i>	<i>RSP $\leq 30 \mu\text{g}/\text{m}^3$ is low conc. range</i>	$24.1 \mu\text{g}/\text{m}^3$	If Tier 1 criteria are not met due to narrow range of PM concentration, during the collocation period, Tier 2 will apply.
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 8 \mu\text{g}/\text{m}^3$ for RSP	$3.4 \mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS


Remark: Follow QAQC Protocol Path 2 which is Criteria Tier 1 failed while Tier 2 passed.

FSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	1.70	<input checked="" type="checkbox"/> FAIL
<i>Linearity (R²)</i>	> 0.70	0.97	<input checked="" type="checkbox"/> PASS
<i>If Tier 1 fails, Conc. Range will be checked</i>	<i>FSP $\leq 25 \mu\text{g}/\text{m}^3$ is low conc. range</i>	$4.4 \mu\text{g}/\text{m}^3$	If Tier 1 criteria are not met due to narrow range of PM concentration, during the collocation period, Tier 2 will apply.
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 5 \mu\text{g}/\text{m}^3$ for FSP	$4.0 \mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS

Remark: Follow QAQC Protocol Path 2 which is Criteria Tier 1 failed while Tier 2 passed.





QAQC Protocol chart flow



Conclusion:

The report approves that each calibrated item of the product meets its technical specifications.
No calibration action is needed during this time.

Prepared by:	Yannis Qiu	Reviewed by:	George Zhang
--------------	------------	--------------	--------------

ONSITE EQUIPMENT VALIDATION RECORD

Product Information:

Report No.:	ZR/T CS.004-2025-10-Z07		
Product Model:	MAS Dust	Serial No.:	dev9204Z250700007
Issue Date:	2025-11-12		
Version	V3.0_20251112		

Traceability of Calibration Instrument:

Test Item	Calibration Instrument
PM _{2.5} (FSP)	Transfer Standard: dev9204Z250800012
PM ₁₀ (RSP)	Location: M03 Pun Uk Tsuen
	Collocation Data Period: 2025-10-17 12:40 to 2025-10-17 15:50

Calibration Result:

RSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	1.43	<input checked="" type="checkbox"/> FAIL
<i>Linearity (R²)</i>	> 0.70	0.89	<input checked="" type="checkbox"/> PASS
<i>If Tier 1 fails, Conc. Range will be checked</i>	$RSP \leq 30 \mu\text{g}/\text{m}^3$ is low conc. range	10.2 $\mu\text{g}/\text{m}^3$	If Tier 1 criteria are not met due to narrow range of PM concentration, during the collocation period, Tier 2 will apply.
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 8 \mu\text{g}/\text{m}^3$ for RSP	4.2 $\mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS


Remark: Follow QAQC Protocol Path 2 which is Criteria Tier 1 failed while Tier 2 passed.

FSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	1.51	<input checked="" type="checkbox"/> FAIL
<i>Linearity (R²)</i>	> 0.70	0.83	<input checked="" type="checkbox"/> PASS
<i>If Tier 1 fails, Conc. Range will be checked</i>	$FSP \leq 25 \mu\text{g}/\text{m}^3$ is low conc. range	4.1 $\mu\text{g}/\text{m}^3$	If Tier 1 criteria are not met due to narrow range of PM concentration, during the collocation period, Tier 2 will apply.
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 5 \mu\text{g}/\text{m}^3$ for FSP	1.2 $\mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS

Remark: Follow QAQC Protocol Path 2 which is Criteria Tier 1 failed while Tier 2 passed.





QAQC Protocol chart flow



Conclusion:

The report approves that each calibrated item of the product meets its technical specifications.
No calibration action is needed during this time.

Prepared by:	Yannis Qiu	Reviewed by:	George Zhang
--------------	------------	--------------	--------------

ONSITE EQUIPMENT VALIDATION RECORD

Product Information:

Report No.:	ZR/T CS.004-2025-11-Z14		
Product Model:	MAS Dust	Serial No.:	dev9204Z250800014
Issue Date:	2025-11-25		
Version	V1.0_20251125		

Traceability of Calibration Instrument:

Test Item	Calibration Instrument
PM _{2.5} (FSP)	Transfer Standard: dev9204Z250800012
PM ₁₀ (RSP)	Location: M06 Mai Po San Tsuen
	Collocation Data Period: 2025-11-24 12:10 to 2025-11-24 15:20

Calibration Result:

RSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	0.93	<input checked="" type="checkbox"/> PASS
<i>Linearity (R²)</i>	> 0.70	0.97	<input checked="" type="checkbox"/> PASS
<i>If Tier 1 fails, Conc. Range will be checked</i>	$RSP \leq 30 \mu\text{g}/\text{m}^3$ is low conc. range	$23.4 \mu\text{g}/\text{m}^3$	Not applicable.
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 8 \mu\text{g}/\text{m}^3$ for RSP	$4.8 \mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS

Remark: Follow QAQC Protocol Path 1 which is Criteria Tier 1 and Tier 2 passed.


FSP:

Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	1.08	<input checked="" type="checkbox"/> PASS
<i>Linearity (R²)</i>	> 0.70	0.54	<input type="checkbox"/> FAIL
<i>If Tier 1 fails, Conc. Range will be checked</i>	$FSP \leq 25 \mu\text{g}/\text{m}^3$ is low conc. range	$2.2 \mu\text{g}/\text{m}^3$	If Tier 1 criteria are not met due to narrow range of PM concentration, during the collocation period, Tier 2 will apply.
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 5 \mu\text{g}/\text{m}^3$ for FSP	$3.7 \mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS


Remark: Follow QAQC Protocol Path 2 which is Criteria Tier 1 failed while Tier 2 passed.




FSP Concentration (2025-11-24)



FSP Correlation with Transfer Standard and Onsite working unit



QAQC Protocol chart flow



Conclusion:

The report approves that each calibrated item of the product meets its technical specifications.
No calibration action is needed during this time.

Prepared by:	Curry Duan	Reviewed by:	Yannis Qiu
--------------	------------	--------------	------------

ONSITE EQUIPMENT VALIDATION RECORD

Product Information:

Report No.:	ZR/T CS.004-2025-11-Z13		
Product Model:	MAS Dust	Serial No.:	dev9204Z250800013
Issue Date:	2025-11-25		
Version	V1.0_20251125		

Traceability of Calibration Instrument:

Test Item	Calibration Instrument
PM _{2.5} (FSP)	Transfer Standard: dev9204Z250800011
PM ₁₀ (RSP)	Location: M11 Shek Wu Wai
	Collocation Data Period: 2025-11-24 12:00 to 2025-11-24 15:10

Calibration Result:

RSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	1.12	<input checked="" type="checkbox"/> PASS
<i>Linearity (R²)</i>	> 0.70	0.96	<input checked="" type="checkbox"/> PASS
<i>If Tier 1 fails, Conc. Range will be checked</i>	$RSP \leq 30 \mu\text{g}/\text{m}^3$ is low conc. range	$16.9 \mu\text{g}/\text{m}^3$	Not applicable.
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 8 \mu\text{g}/\text{m}^3$ for RSP	$1.9 \mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS


Remark: Follow QAQC Protocol Path 1 which is Criteria Tier 1 and Tier 2 passed.

FSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	0.97	<input checked="" type="checkbox"/> PASS
<i>Linearity (R²)</i>	> 0.70	0.97	<input checked="" type="checkbox"/> PASS
<i>If Tier 1 fails, Conc. Range will be checked</i>	$FSP \leq 25 \mu\text{g}/\text{m}^3$ is low conc. range	$5.6 \mu\text{g}/\text{m}^3$	Not applicable.
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 5 \mu\text{g}/\text{m}^3$ for FSP	$0.3 \mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS

Remark: Follow QAQC Protocol Path 1 which is Criteria Tier 1 and Tier 2 passed.





QAQC Protocol chart flow



Conclusion:

The report approves that each calibrated item of the product meets its technical specifications.
No calibration action is needed during this time.

Prepared by:	Curry Duan	Reviewed by:	Yannis Qiu
--------------	------------	--------------	------------

ONSITE EQUIPMENT VALIDATION RECORD

Product Information:

Report No.:	ZR/T CS.004-2025-11-Z15		
Product Model:	MAS Dust	Serial No.:	dev9204Z250800015
Issue Date:	2025-11-25		
Version	V1.0_20251125		

Traceability of Calibration Instrument:

Test Item	Calibration Instrument
PM _{2.5} (FSP)	Transfer Standard: dev9204Z250800012
PM ₁₀ (RSP)	Location: M14 Rolling Hill – Outside of Rolling Hill Collocation Data Period: 2025-11-24 18:10 to 2025-11-24 21:20

Calibration Result:

RSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	0.79	<input checked="" type="checkbox"/> PASS
<i>Linearity (R²)</i>	> 0.70	0.98	<input checked="" type="checkbox"/> PASS
<i>If Tier 1 fails, Conc. Range will be checked</i>	<i>RSP $\leq 30 \mu\text{g}/\text{m}^3$ is low conc. range</i>	33.8 $\mu\text{g}/\text{m}^3$	If Tier 1 criteria are not met due to narrow range of PM concentration, during the collocation period, Tier 2 will apply.
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 8 \mu\text{g}/\text{m}^3$ for RSP	4.0 $\mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS



Remark: Follow QAQC Protocol Path 1 which is Criteria Tier 1 and Tier 2 passed.

FSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	1.34	<input checked="" type="checkbox"/> FAIL
<i>Linearity (R²)</i>	> 0.70	0.70	<input checked="" type="checkbox"/> FAIL
<i>If Tier 1 fails, Conc. Range will be checked</i>	<i>FSP $\leq 25 \mu\text{g}/\text{m}^3$ is low conc. range</i>	2.2 $\mu\text{g}/\text{m}^3$	If Tier 1 criteria are not met due to narrow range of PM concentration, during the collocation period, Tier 2 will apply.
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 5 \mu\text{g}/\text{m}^3$ for FSP	2.8 $\mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS

Remark: Follow QAQC Protocol Path 2 which is Criteria Tier 1 failed while Tier 2 passed.





QAQC Protocol chart flow



Conclusion:

The report approves that each calibrated item of the product meets its technical specifications.
No calibration action is needed during this time.

Prepared by:	Curry Duan	Reviewed by:	Yannis Qiu
--------------	------------	--------------	------------

ONSITE EQUIPMENT VALIDATION RECORD

Product Information:

Report No.:	ZR/T CS.004-2025-11-Z16		
Product Model:	MAS Dust	Serial No.:	dev9204Z250800016
Issue Date:	2025-11-25		
Version	V1.0_20251125		

Traceability of Calibration Instrument:

Test Item	Calibration Instrument
PM _{2.5} (FSP)	Transfer Standard: dev9204Z250800011
PM ₁₀ (RSP)	Location: M13 Rolling Hill – Rooftop Area
	Collocation Data Period: 2025-11-24 18:10 to 2025-11-24 21:20

Calibration Result:

RSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	1.00	<input checked="" type="checkbox"/> PASS
<i>Linearity (R²)</i>	> 0.70	0.99	<input checked="" type="checkbox"/> PASS
<i>If Tier 1 fails, Conc. Range will be checked</i>	$RSP \leq 30 \mu\text{g}/\text{m}^3$ is low conc. range	$42.3 \mu\text{g}/\text{m}^3$	Not applicable.
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 8 \mu\text{g}/\text{m}^3$ for RSP	$3.7 \mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS


Remark: Follow QAQC Protocol Path 1 which is Criteria Tier 1 and Tier 2 passed.

FSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	1.17	<input checked="" type="checkbox"/> PASS
<i>Linearity (R²)</i>	> 0.70	0.85	<input checked="" type="checkbox"/> PASS
<i>If Tier 1 fails, Conc. Range will be checked</i>	$FSP \leq 25 \mu\text{g}/\text{m}^3$ is low conc. range	$5.7 \mu\text{g}/\text{m}^3$	If Tier 1 criteria are not met due to narrow range of PM concentration, during the collocation period, Tier 2 will apply.
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 5 \mu\text{g}/\text{m}^3$ for FSP	$4.4 \mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS

Remark: Follow QAQC Protocol Path 1 which is Criteria Tier 1 and Tier 2 passed.





QAQC Protocol chart flow



Conclusion:

The report approves that each calibrated item of the product meets its technical specifications.
No calibration action is needed during this time.

Prepared by:	Curry Duan	Reviewed by:	Yannis Qiu
--------------	------------	--------------	------------



ONSITE EQUIPMENT VALIDATION RECORD

Product Information:

Report No.:	ZR/T CS.004-2025-11-Z19		
Product Model:	MAS Dust	Serial No.:	dev9204Z250900019
Issue Date:	2025-11-21		
Version	V1.0_20251121		

Traceability of Calibration Instrument:

Test Item	Calibration Instrument
PM _{2.5} (FSP)	Transfer Standard: dev9204Z250800011
PM ₁₀ (RSP)	Location: M15a The STEP
	Collocation Data Period: 2025-11-17 12:40 to 2025-11-17 15:50

Calibration Result:

RSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	1.97	<input checked="" type="checkbox"/> FAIL
<i>Linearity (R²)</i>	> 0.70	0.76	<input checked="" type="checkbox"/> PASS
<i>If Tier 1 fails, Conc. Range will be checked</i>	$RSP \leq 30 \mu\text{g}/\text{m}^3$ is low conc. range	10.9 $\mu\text{g}/\text{m}^3$	If Tier 1 criteria are not met due to narrow range of PM concentration, during the collocation period, Tier 2 will apply.
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 8 \mu\text{g}/\text{m}^3$ for RSP	5.0 $\mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS


Remark: Follow QAQC Protocol Path 2 which is Criteria Tier 1 failed while Tier 2 passed.

FSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	1.27	<input checked="" type="checkbox"/> FAIL
<i>Linearity (R²)</i>	> 0.70	0.99	<input checked="" type="checkbox"/> PASS
<i>If Tier 1 fails, Conc. Range will be checked</i>	$FSP \leq 25 \mu\text{g}/\text{m}^3$ is low conc. range	7.7 $\mu\text{g}/\text{m}^3$	If Tier 1 criteria are not met due to narrow range of PM concentration, during the collocation period, Tier 2 will apply.
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 5 \mu\text{g}/\text{m}^3$ for FSP	1.7 $\mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS

Remark: Follow QAQC Protocol Path 2 which is Criteria Tier 1 failed while Tier 2 passed.





QAQC Protocol chart flow



Conclusion:

The report approves that each calibrated item of the product meets its technical specifications.
No calibration action is needed during this time.

Prepared by:	Curry Duan	Reviewed by:	Yannis Qiu
--------------	------------	--------------	------------

ONSITE EQUIPMENT VALIDATION RECORD

Product Information:

Report No.:	ZR/T CS.004-2025-11-Z05		
Product Model:	MAS Dust	Serial No.:	dev9204Z250700005
Issue Date:	2025-11-21		
Version	V1.0_20251121		

Traceability of Calibration Instrument:

Test Item	Calibration Instrument
PM _{2.5} (FSP)	Transfer Standard: dev9204Z250800011
PM ₁₀ (RSP)	Location: M09 Wing Ping Tsuen
	Collocation Data Period: 2025-11-17 05:20 to 2025-11-17 08:30

Calibration Result:

RSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	0.82	<input checked="" type="checkbox"/> PASS
<i>Linearity (R²)</i>	> 0.70	0.95	<input checked="" type="checkbox"/> PASS
<i>If Tier 1 fails, Conc. Range will be checked</i>	$RSP \leq 30 \mu\text{g}/\text{m}^3$ is low conc. range	$12.6 \mu\text{g}/\text{m}^3$	Not applicable
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 8 \mu\text{g}/\text{m}^3$ for RSP	$1.9 \mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS


Remark: Follow QAQC Protocol Path 1 which both Criteria Tier 1 and Tier 2 passed.

FSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	0.99	<input checked="" type="checkbox"/> PASS
<i>Linearity (R²)</i>	> 0.70	0.94	<input checked="" type="checkbox"/> PASS
<i>If Tier 1 fails, Conc. Range will be checked</i>	$FSP \leq 25 \mu\text{g}/\text{m}^3$ is low conc. range	$2.1 \mu\text{g}/\text{m}^3$	Not applicable
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 5 \mu\text{g}/\text{m}^3$ for FSP	$1.4 \mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS

Remark: Follow QAQC Protocol Path 1 which both Criteria Tier 1 and Tier 2 passed.





QAQC Protocol chart flow



Conclusion:

The report approves that each calibrated item of the product meets its technical specifications.
No calibration action is needed during this time.

Prepared by:	Curry Duan	Reviewed by:	Yannis Qiu
--------------	------------	--------------	------------

ONSITE EQUIPMENT VALIDATION RECORD

Product Information:

Report No.:	ZR/T CS.004-2025-11-Z07		
Product Model:	MAS Dust	Serial No.:	dev9204Z250700007
Issue Date:	2025-11-21		
Version	V1.0_20251121		

Traceability of Calibration Instrument:

Test Item	Calibration Instrument
PM _{2.5} (FSP)	Transfer Standard: dev9204Z250800012
PM ₁₀ (RSP)	Location: M03 Pun Uk Tsuen
	Collocation Data Period: 2025-11-17 12:40 to 2025-11-17 15:50

Calibration Result:

RSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	0.98	<input checked="" type="checkbox"/> PASS
<i>Linearity (R²)</i>	> 0.70	0.97	<input checked="" type="checkbox"/> PASS
<i>If Tier 1 fails, Conc. Range will be checked</i>	$RSP \leq 30 \mu\text{g}/\text{m}^3$ is low conc. range	$11.5 \mu\text{g}/\text{m}^3$	Not applicable
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 8 \mu\text{g}/\text{m}^3$ for RSP	$0.9 \mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS


Remark: Follow QAQC Protocol Path 1 which both Criteria Tier 1 and Tier 2 passed.

FSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	1.36	<input type="checkbox"/> FAIL
<i>Linearity (R²)</i>	> 0.70	1.00	<input checked="" type="checkbox"/> PASS
<i>If Tier 1 fails, Conc. Range will be checked</i>	$FSP \leq 25 \mu\text{g}/\text{m}^3$ is low conc. range	$5.6 \mu\text{g}/\text{m}^3$	If Tier 1 criteria are not met due to narrow range of PM concentration, during the collocation period, Tier 2 will apply.
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 5 \mu\text{g}/\text{m}^3$ for FSP	$2.5 \mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS

Remark: Follow QAQC Protocol Path 2 which is Criteria Tier 1 failed while Tier 2 passed.





QAQC Protocol chart flow



Conclusion:

The report approves that each calibrated item of the product meets its technical specifications.
No calibration action is needed during this time.

Prepared by:	Curry Duan	Reviewed by:	Yannis Qiu
--------------	------------	--------------	------------

ONSITE EQUIPMENT VALIDATION RECORD

Product Information:

Report No.:	ZR/T CS.004-2025-11-Z06		
Product Model:	MAS Dust	Serial No.:	dev9204Z250700006
Issue Date:	2025-11-21		
Version	V1.0_20251121		

Traceability of Calibration Instrument:

Test Item	Calibration Instrument
PM _{2.5} (FSP)	Transfer Standard: dev9204Z250800012
PM ₁₀ (RSP)	Location: M04 Chau Tau Tsuen
	Collocation Data Period: 2025-11-17 05:20 to 2025-11-17 08:30

Calibration Result:

RSP:


Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	0.94	<input checked="" type="checkbox"/> PASS
<i>Linearity (R²)</i>	> 0.70	0.70	<input checked="" type="checkbox"/> PASS
<i>If Tier 1 fails, Conc. Range will be checked</i>	$RSP \leq 30 \mu\text{g}/\text{m}^3$ is low conc. range	$15.6 \mu\text{g}/\text{m}^3$	Not applicable
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 8 \mu\text{g}/\text{m}^3$ for RSP	$3.1 \mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS

Remark: Follow QAQC Protocol Path 1 which both Criteria Tier 1 and Tier 2 passed.


FSP:

Performance Metric	Target Value	Actual Value	Result
<u>Tier 1</u>			
<i>Bias (Slope)</i>	1.00 ± 0.25	-0.67	<input type="checkbox"/> FAIL
<i>Linearity (R²)</i>	> 0.70	0.75	<input checked="" type="checkbox"/> PASS
<i>If Tier 1 fails, Conc. Range will be checked</i>	$FSP \leq 25 \mu\text{g}/\text{m}^3$ is low conc. range	$2.9 \mu\text{g}/\text{m}^3$	If Tier 1 criteria are not met due to narrow range of PM concentration, during the collocation period, Tier 2 will apply.
<u>Tier 2</u>			
<i>Error (RMSE)</i>	$< 5 \mu\text{g}/\text{m}^3$ for FSP	$4.9 \mu\text{g}/\text{m}^3$	<input checked="" type="checkbox"/> PASS


Remark: Follow QAQC Protocol Path 2 which is Criteria Tier 1 failed while Tier 2 passed.




FSP Concentration (2025-11-17)



FSP Correlation with Transfer Standard and Onsite working unit



QAQC Protocol chart flow



Conclusion:

The report approves that each calibrated item of the product meets its technical specifications.
No calibration action is needed during this time.

Prepared by:	Curry Duan	Reviewed by:	Yannis Qiu
--------------	------------	--------------	------------